

Addendum #2 to SJPC-PDD-112321: Questions from Potential Bidders – November 8, 2021

Q1: Can you provide additional drawings for the SSP cell arc radius and Bollard installation drawings.

A1: Historic as-built drawings of the SSP Cell arc radius and bollards are not available.

Q2: Do we need to reinstall or attach the impress current bars to the new steel.

A2: Yes, the impressed current bar is to be reinstalled.

Q3: Angle is getting backer rod installed to hold the epoxy in to make the bottom seal. Is it also going to be used on the rolled plate? Or requiring steel bottom plates installed.

A3: Cross-Section shown on page 7 shows a steel bottom plate.

Q4: Do the rolled plate require factory applied epoxy coatings.

A4: Yes, everything should be factory coated.