

**Addendum 1
April 8, 2025
South Jersey Port Corporation
SJPC-RFP-25-46
Building A & B Scupper Repairs Balzano Marine Terminal**

NOTICE

This Addendum is considered part of this Request for Proposals and must be acknowledged with your submission.

ANSWERS TO FORMALLY SUBMITTED QUESTIONS

Please see the attached revised drawings. The revised drawings indicate 6" diameter downspouts and 6" roof drainpipe at the scuppers, and the replacement of the existing gutter at A Building.